



SUBURBAN TESTING LABS

Results Report

Order ID: 7084268

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: Oakland, NJ PS - Manito Elementary School
111 Manito Avenue
Oakland, NJ 07436

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7084268-01
Collector: KM

Site: OM-BLANK-PR
Collect Date: 08/18/2017 11:59 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/21/17 RPV 08/22/17 12:29 RPV

Sample Number: 7084268-02
Collector: KM

Site: OM-FP-1FL-KITCHENAUX-PR
Collect Date: 08/18/2017 12:00 pm

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.45 µg/L EPA 200.8 1.00 1 08/21/17 RPV 08/22/17 12:31 RPV

Sample Number: 7084268-03
Collector:

Site: Laboratory Control Sample
Collect Date: 08/21/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.5 µg/L EPA 200.8 1.00 1 08/21/17 RPV 08/22/17 12:35 RPV

Sample Number: 7084268-04
Collector:

Site: Laboratory Control Sample Duplicate
Collect Date: 08/21/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.0 µg/L EPA 200.8 1.00 1 08/21/17 RPV 08/22/17 12:37 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 08/23/2017 4:58 pm 7084268

STL_Results Revision #1.6

Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605

Phone: 610-433-6695

Fax: 610-375-4090

suburbantestinglabs.com



PADEP 06-00208