



### Results Report

Order ID: 7073551

Karl Environmental Group  
20 Lauck Road  
Mohnton, PA 19540

Project: Oakland, NJ PS - Manito Elementary School  
111 Manito Avenue  
Oakland, NJ 07436

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7073551-01      Site: OM-BLANK-FLUSH      Sample ID:  
Collector: KM      Collect Date: 07/14/2017 7:42 am      Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      07/15/17      RPV      07/28/17 17:57      RPV

Sample Number: 7073551-02      Site: OM-FP-1FL-KITCHENAUX-FLUSH      Sample ID:  
Collector: KM      Collect Date: 07/14/2017 7:43 am      Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      3.83      µg/L      EPA 200.8      1.00      1      07/15/17      RPV      07/28/17 17:59      RPV

Sample Number: 7073551-03      Site: Laboratory Control Sample      Sample ID:  
Collector:      Collect Date: 07/14/2017 12:00 am      Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      15.5      µg/L      EPA 200.8      1.00      1      07/15/17      RPV      07/28/17 18:01      RPV

Sample Number: 7073551-04      Site: Laboratory Control Sample Duplicate      Sample ID:  
Collector:      Collect Date: 07/14/2017 12:00 am      Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead      15.5      µg/L      EPA 200.8      1.00      1      07/15/17      RPV      07/28/17 18:03      RPV

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 07/31/2017 2:33 pm      7073551  
STL\_Results      Revision #1.6      Effective: 07/09/2014





# SUBURBAN TESTING LABS

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.


Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Alana Kopicz  
Project Manager

Report Generated On: 07/31/2017 2:33 pm 7073551  
STL\_Results Revision #1.6 Effective: 07/09/2014





7073551  
Alana Kopicz

TAT(Check One):  Standard  24hr  48hr  72hr  Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Karl Environmental Group

Address: 20 Lauck Road  
Mohnton, PA 19540

Contact Name: Kelly Mays

Phone: \_\_\_\_\_  
Fax: 610-856-5040  
Email: kmays@karlenv.com

Client Name: Oakland Public Schools Lead in Water

Address: Manito Elementary School  
111 Manito Avenue, Oakland, NJ 07436

Payment / P.O. Info: 17-0525

Comments:

**NJ DOE Lead in Drinking Water Samples - Second Draw**

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OM-BLANK-FLUSH	7/14/2017	0742	KM	Lead <i>pH &lt; 2</i> ↓	1	PW	G	P	H	BLANK
	OM-FP-1FL-KITCHENAUX-FLUSH	7/14/2017	0743	KM	Lead	1	PW	G	P	H	
					<i>pH ✓ JSE 7-14-17</i>						

Relinquished By: <i>Kelly Mays</i>	Date: <u>7-14-17</u> Time: <u>1205</u>	Temp °C: _____ Acceptable: Y / N	<b>Sample Conditions</b>	<b>Matrix Key</b> NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	<b>Bottle Type Key</b> P = Plastic G = Glass O = Other	<b>Reporting Options</b> <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <i>[Signature]</i>	Date: <u>7/14/17</u> Time: <u>1205</u>		<b>Number of containers match number on COC?</b> Y / N			
Relinquished By: <i>[Signature]</i>	Date: <u>7/14/17</u> Time: <u>1503</u>	Temp °C: _____ Acceptable: Y / N	All containers in tact? Y / N	<b>Sample Type Key</b> G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	<b>SDWA Sample Types</b> D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	<b>Preservative Key</b> N = Sodium Thiosulfate A = Ascorbic Acid H = HNO <sub>3</sub> C = HCl S = H <sub>2</sub> SO <sub>4</sub> OH = NaOH O = Other NA = None Required
Received in Lab By: <i>[Signature]</i>	Date: <u>7/14/17</u> Time: <u>1503</u>	Temp °C: <u>11.6</u> Acceptable: <input checked="" type="checkbox"/> Y / N	Tests within holding times Y / N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.