



SUBURBAN TESTING LABS

Results Report

Order ID: 7084266

Karl Environmental Group 20 Lauck Road Mohnton, PA 19540	Project: Oakland, NJ PS - Valley Middle School 71 Oak Street Oakland, NJ 07436
Attn: Kelly Mays	Regulatory ID:

Sample Number: 7084266-01	Site: OV-BLANK-PR	Sample ID:
Collector: KM	Collect Date: 08/18/2017 11:14 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/21/17	RPV	08/22/17 12:10	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7084266-02	Site: OV-NS-1FL-NURSE-PR	Sample ID:
Collector: KM	Collect Date: 08/18/2017 11:17 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	31.3	µg/L	EPA 200.8	1.00	1	08/21/17	RPV	08/22/17 12:04	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7084266-03	Site: OV-FP-1FL-KITCHEN-PR	Sample ID:
Collector: KM	Collect Date: 08/18/2017 11:19 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/21/17	RPV	08/22/17 12:12	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7084266-04	Site: OV-FP-1FL-HOMEEC-2-PR	Sample ID:
Collector: KM	Collect Date: 08/18/2017 11:24 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/21/17	RPV	08/22/17 12:14	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7084266-05	Site: OV-FP-1FL-HOMEEC-1-PR	Sample ID:
Collector: KM	Collect Date: 08/18/2017 11:25 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.32	µg/L	EPA 200.8	1.00	1	08/21/17	RPV	08/22/17 12:16	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 08/23/2017 4:59 pm 7084266
 STL_Results Revision #1.6 Effective: 07/09/2014

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6695 Fax: 610-375-4090 suburbantestinglabs.com



PADEP 06-00208