



Results Report

Order ID: 7063410

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: Oakland, NJ PS - Valley Middle School
71 Oak Street
Oakland, NJ 07436

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7063410-01
Collector: DT

Site: OV-BLANK
Collect Date: 06/19/2017 11:09 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 06/25/17 RJS 06/26/17 18:34 RPV

Sample Number: 7063410-02
Collector: DT

Site: OV-WC-1FL-CAFE
Collect Date: 06/19/2017 11:15 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.9 µg/L EPA 200.8 1.00 1 06/25/17 RJS 06/26/17 18:36 RPV

Sample Number: 7063410-03
Collector: DT

Site: OV-DW-1FL-CAFEHALL-1
Collect Date: 06/19/2017 11:17 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.0 µg/L EPA 200.8 1.00 1 06/25/17 RJS 06/26/17 18:46 RPV

Sample Number: 7063410-04
Collector: DT

Site: OV-DW-1FL-CAFEHALL-2
Collect Date: 06/19/2017 11:18 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 42.2 µg/L EPA 200.8 1.00 1 06/25/17 RJS 06/26/17 18:48 RPV

Sample Number: 7063410-05
Collector: DT

Site: OV-NS-1FL-NURSE
Collect Date: 06/19/2017 11:19 am

Sample ID:
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 16.7 µg/L EPA 200.8 1.00 1 06/25/17 RJS 06/26/17 20:34 RPV

Report Generated On: 07/05/2017 3:47 pm
STL_Results Revision #1.6

7063410
Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7063410-06	Site: OV-WC-1FL-200WING-2	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:21 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.37	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:40	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-07	Site: OV-WC-1FL-200WING-1	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:20 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.22	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:46	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-08	Site: OV-FP-1FL-KITCHEN	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:25 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	21.3	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:48	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-09	Site: OV-TL-1FL-FACULTY	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:27 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.38	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:50	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-10	Site: OV-WC-1BL-LOWER30SHALL	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:43 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	6.04	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:56	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-11	Site: OV-WC-1FL300-WING-1	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:30 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.03	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 19:58	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-12	Site: OV-WC-1FL300-WING-2	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:31 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.37	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:00	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 07/05/2017 3:47 pm 7063410
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7063410-13	Site: OV-DW-1FL-GYMHALL-1	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:33 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.59	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:02	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-14	Site: OV-DW-1FL-GYMHALL-2	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:34 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	13.9	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:04	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-15	Site: OV-OV-FP-1FL-HOMECC-4	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:35 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	10.1	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:06	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-16	Site: OV-OV-FP-1FL-HOMECC-3	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:36 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	10.9	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:08	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-17	Site: OV-FP-1FL-HOMECC-2	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:37 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.4	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:12	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-18	Site: OV-FP-1FL-HOMECC-1	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:38 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	16.0	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:14	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-19	Site: OV-WC-2FL-50SHALL	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:44 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.45	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:20	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 07/05/2017 3:47 pm 7063410
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 7063410-20	Site: OV-TL-2FL-FACULTY	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:46 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	29.2	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:22	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-21	Site: OV-WC-2FL-UPPER30SHALL	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:47 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.89	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:24	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-22	Site: OV-TL-2FL-BOARDSTAFF	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:50 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	30.0	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:26	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-23	Site: OV-TL-2FL-SUPER	Sample ID:
Collector: DT	Collect Date: 06/19/2017 11:53 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	13.6	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:28	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-24	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 06/19/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.8	µg/L	EPA 200.8	1.00	1	06/25/17	RJS	06/26/17 20:30	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7063410-25	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 06/19/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.5	µg/L	EPA 200.8	1.00	1	06/20/17	RPV	07/03/17 22:58	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 07/05/2017 3:47 pm 7063410
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz
Project Manager

Report Generated On: 07/05/2017 3:47 pm 7063410
STL_Results Revision #1.6 Effective: 07/09/2014





7063410
Alana Kopicz

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton, PA 19540
Phone: 610-856-7700
Contact Name: Kelly Mays
Email: kmays@karlenv.com
Fax: 610-856-5040

Project Name: Oakland Public Schools Lead in Water
Address: Valley Middle School
71 Oak Street, Oakland, NJ 07436
Payment / P.O. Info: 17-0525

Comments: NJ DOE Lead in Drinking Water Samples - First Draw

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OV-BLANK	6/17/2017	1109	DT	Lead	1	PW	G	P	H	BLANK
	OV-WC-1FL-CAFÉ	6/17/2017	1115	DT	Lead	1	PW	G	P	H	
	OV-DW-1FL-CAFHALL-1	6/17/2017	1117	DT	Lead	1	PW	G	P	H	
	OV-DW-1FL-CAFHALL-2	6/17/2017	1118	DT	Lead	1	PW	G	P	H	
	OV-NS-1FL-NURSE	6/17/2017	1119	DT	Lead	1	PW	G	P	H	
	OV-WC-1FL-200WING-2	6/17/2017	1121	DT	Lead	1	PW	G	P	H	
	OV-WC-1FL-200WING-1	6/17/2017	1120	DT	Lead	1	PW	G	P	H	
	OV-FP-1FL-KITCHEN	6/17/2017	1125	DT	Lead	1	PW	G	P	H	

Relinquished By: <u>D. Townsena</u>	Date: <u>6-17-17</u> Time: <u>13:00</u>	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
Received By: <u>Kelly Mays</u>	Date: <u>6-17-17</u> Time: <u>1300</u> Temp °C: _____ Acceptable: Y / N	
Relinquished By: <u>Kelly Mays</u>	Date: <u>6-19-17</u> Time: <u>1247</u> Temp °C: _____ Acceptable: Y / N	
Received in Lab By: <u>[Signature]</u> (8)	Date: <u>6/19/17</u> Time: <u>12:47</u> Temp °C: <u>12.9</u> on ice Acceptable: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective Novemr
Shaded areas are for SWTL use only.


Suburban Testing Labs

Lab Date/Time: 6/19/17 13:01 Lab Temp: 12.9

- Number of containers/coolers match number on COC? Y N
- Sample lables and COC are free of discrepancies? Y N
- All Containers in tact? Y N
- Received in lab within acceptable temperature limits? Y N
- 40mL VOA vials free of headspace? Y N

Relinquished by: [Signature] (8)

Received in Lab by: [Signature] 6/19/17



7063410
Alana Kopicz

TAT (Check One): Standard 24hr 48hr 72hr Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton, PA 19540
Phone: 610-856-7700
Fax: 610-856-5040
Contact Name: Kelly Mays
Email: kmays@karlenv.com

Project Name: Oakland Public Schools Lead in Water
Address: Valley Middle School
71 Oak Street, Oakland, NJ 07436
Payment / P.O. Info: 17-0525

Comments: NJ DOE Lead in Drinking Water Samples - First Draw

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OV-TL-1FL-FACULTY	6/17/2017	1127	DT	Lead	1	PW	G	P	H	pH < 2 ↓
	OV-WC-1BL-LOWER30SHALL	6/17/2017	1143	DT	Lead	1	PW	G	P	H	
	OV-WC-1FL-300WING-1	6/17/2017	1136	DT	Lead	1	PW	G	P	H	
	OV-WC-1FL-300WING-2	6/17/2017	1131	DT	Lead	1	PW	G	P	H	
	OV-DW-1FL-GYMHALL-1	6/17/2017	1133	DT	Lead	1	PW	G	P	H	
	OV-DW-1FL-GYMHALL-2	6/17/2017	1134	DT	Lead	1	PW	G	P	H	
	OV-FP-1FL-HOME EC-4	6/17/2017	1135	DT	Lead	1	PW	G	P	H	
	OV-FP-1FL-HOME EC-3	6/17/2017	1136	DT	Lead	1	PW	G	P	H	

Relinquished By: <u>D. Townsend</u>	Date: <u>6-17-17</u> Time: <u>13:00</u>	Temp °C: _____ Acceptable: Y / N	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N All containers in tact? <input checked="" type="checkbox"/> Y / N Tests within holding times? <input checked="" type="checkbox"/> Y / N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y / N
Received By: <u>Kelly Mays</u>	Date: <u>6-17-17</u> Time: <u>1300</u>		
Relinquished By: <u>Kelly Mays</u>	Date: <u>6-19-17</u> Time: <u>1247</u>	Temp °C: <u>12.9 on ice</u> Acceptable: <input checked="" type="checkbox"/> Y / N	
Received in Lab By: <u>Lon B. Gou</u>	Date: <u>6/19/17</u> Time: <u>12:47</u>		

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective Novem
Shaded areas are for SWTL use only.

Suburban Testing Labs

Lab Date/Time: 6/19/17 13:01 Lab Temp: 12.9

Number of containers/coolers match number on COC? Y / N
Sample lables and COC are free of discrepancies? Y / N
All Containers in tact? Y / N
Received in lab within acceptable temperture limits? Y / N
40mL VOA vials free of headspace? Y / N

Relinquished by: Lon B. Gou (8)

Received in Lab by: AMS 6/19/17 13:01



SUBURBAN TESTING LABS



7063410
Alana Kopicz

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road Phone: 610-856-7700
Mohnton, PA 19540 Fax: 610-856-5040
Contact Name: Kelly Mays Email: kmays@karlenv.com

Project Name: Oakland Public Schools Lead in Water
Address: Valley Middle School
71 Oak Street, Oakland, NJ 07436
Payment / P.O. Info: 17-0525

Comments:
NJ DOE Lead in Drinking Water Samples - First Draw

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OV-FP-1FL-HOMEEC-2	6/17/2017	1137	DT	Lead	1	PW	G	P	H	} PHC2
	OV-FP-1FL-HOMEEC-1	6/17/2017	1138	DT	Lead	1	PW	G	P	H	
	OV-WC-2FL-50SHALL	6/17/2017	1144	DT	Lead	1	PW	G	P	H	
	OV-TL-2FL-FACULTY	6/17/2017	1146	DT	Lead	1	PW	G	P	H	
	OV-WC-2FL-UPPER30SHALL	6/17/2017	1147	DT	Lead	1	PW	G	P	H	
	OV-TL-2FL-BOARDSTAFF	6/17/2017	1150	DT	Lead	1	PW	G	P	H	
	OV-TL-2FL-SUPER	6/17/2017	1153	DT	Lead	1	PW	G	P	H	

Relinquished By: <u>D. Townsend</u>	Date: <u>6-17-17</u> Time: <u>13:00</u>		Sample Conditions
Received By: <u>Kelly Mays</u>	Date: <u>6-17-17</u> Time: <u>1300</u>	Temp °C: _____ Acceptable: Y / N	Submitted with COC? <input type="radio"/> N
Relinquished By: <u>Kelly Mays</u>	Date: <u>6-19-17</u> Time: <u>1247</u>	Temp °C: _____ Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="radio"/> Y
Received in Lab By: <u>[Signature]</u>	Date: <u>6/19/17</u> Time: <u>12:47</u>	Temp °C: <u>12.9</u> Acceptable: <input checked="" type="radio"/> Y <input type="radio"/> N <u>on ice</u>	All containers in tact? <input type="radio"/> N
			Tests within holding times <input checked="" type="radio"/> Y <input type="radio"/> N
			40 mL VOA vials free of headspace? <input type="radio"/> Y <input type="radio"/> N

Suburban Testing Labs

Lab Date/Time: 6/19/17 13:01 Lab Temp: 12.9

Number of containers/coolers match number on COC? Y N
Sample labels and COC are free of discrepancies? Y N
All Containers in tact? Y N
Received in lab within acceptable temperature limits? Y N
40mL VOA vials free of headspace? Y N

Relinquished by: [Signature] 7

Received in Lab by: [Signature] 6/19/17 13:01

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November
Shaded areas are for SWTL use only.